WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44262
Permit No.
Basin Z-24

NOTICE OF INTENT NO. 49309

1. OWNER Michael R. Stewart
MAILING ADDRESS P.O. Box 40
Empire, Nev. 89405

ADDRESS AT WELL LOCATION

2. LOCATION Lot #1 ¼ Sec. 1 T. 35N N/S R. 23 E. Washoe County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brn Sandy top soil		0	15	15
Brn. Med Coarse Sand		15	25	10
Brn, Red Sh clayey pebble gravel		30	40	10
Brn Pebbly med. Coarse Sand		40	45	5
Brn Silty Sandy Pea gravel		45	55	10
Brn Gray Coarse Sandy Pea Gravel		55	60	5
Gray Pebble Gravel		60	65	5
Gray-Brn. silty Coarse Sand		65	70	5
+ gravel w/angular vol. cx.		~~70~~	~~105~~	
Brn Fine Sand		70	105	35
Brn - gray Clayey Coarse Sand-gravel		105	115	10
Gray - Red Sandy gravel		115	120	5
Gray Sandy Gravel		120	140	20
gray Tan Sandy Gravel - Lake Sed.		140	145	5
Silty Sand w/minor Pebbles		145	150	5
Brn Gray Coarse gravel		150	165	15
AA w/ white Frags. vol Ash		165	190	25
Sandy gravel, w/Frag Lake Sed.		190	205	15
Brn Gray silty Sand + gravel		205	245	40
Brn. Gray silty Sand		245	330	85
Gray Siltstone. minor Sand		330	540	210
Well was plugged				
after Pilot Hole - Barrid				
Plug it Weight 9.4 - Neat				
Cement from 105 ft to 65 ft.				

Date started 2-27-, 1994
Date completed 2-29, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150		2hrs

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased N.A. Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	540 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	N.A.			

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From N.A. feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name San. Emidio Resources (Contractor)
Address P.O. Box 40 Empire, Nev. 89405 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1558
Signed Michael W. Clear (By driller performing actual drilling on site or contractor)
Date 3-22-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627