WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44275
Permit No.
Basin 49

NOTICE OF INTENT NO. 23307

1. OWNER MARTIN KRAFT
MAILING ADDRESS 611 Bullion Rd 43 Elko NV 89801
ADDRESS AT WELL LOCATION 3443 Wright WAY Elko NV

2. LOCATION NE¼SW¼ SE¼NW¼ Sec. 8 T. 34 N/S R. 55 E/W Elko County
PERMIT NO. (Issued by Water Resources) 06-095-056 (Parcel No.) Government Tracts Section 8 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	8	8
Gravel		8	10	2
CLAY		10	24	14
Hard Rock		24	95	71
CLAY		95	103	8
Cemented Gravel		103	111	8
CLAY		111	124	13
Cemented Gravel		124	190	66
CLAY		190	211	101
Cemented Gravel		211	284	73
CLAY		284	327	43
White Cemented SANDSTONE		327	458	131
Soft white SANDSTONE	X	458	505	47
Black wood		505	506	1
Soft white SANDSTONE	X	506	510	4

APR 25 P1:27 '94 STATE ENGINEER

Date started 3-21, 1994
Date completed 4-5, 1994

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40-45		6.5

8. WELL CONSTRUCTION
Depth Drilled 510 Feet Depth Cased 510 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
8 7/8 Inches		60 Feet	510 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	510

Perforations:
Type perforation Slot 5
Size perforation 3/16 x 3"
From 460 feet to 510 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 510 feet

9. WATER LEVEL
Static water level 260 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ferrig Drilling Co (Contractor)
Address P.O. Box 525 (Contractor)
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-13-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627