WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44377
Permit No.
Basin 24

NOTICE OF INTENT NO.

1. OWNER Michael B. Stewart
MAILING ADDRESS P.O. Box 40
Empire, Nev. 89405

ADDRESS AT WELL LOCATION Orient Farms
P.O. Box 152 Gerlach, Nev. 89412
25 mi North Gerlach

2. LOCATION NE ¼ NW ¼ Sec. 12 T. 35 N N/S R. 23 E. Washoe County

PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☑ Other Plug

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The original well was plugged - Replacement well was redrilled.				
Casing collaposed in original well at 230 ft. Went in with 6¼ Bit to 350 Cleaned out with Baroid pluggit with a VIS 78 circulated to the top. Let well set over weekend Fluid fell to 80 ft. Filled hole to 50 ft. Dia Log Shot four ½ holes in Casing So fluid get penetrate back side of casing. Poured 5 yds Concreted mix in top of hole to finish plugging.				

'94 JUN -6 AM
STATE ENGINEERS

Date started 5-6-94, 19
Date completed 5-9-94, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation 3/16 Slot
Size perforation
From 60 feet to 354 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL

Static water level 122 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name San Emidio Resources
Contractor
Address P.O. Box 40
Contractor
Empire, Nev. 89405

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1558

Signed Michael W. Claar
By driller performing actual drilling on site or contractor

Date 6-2-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627