

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 14784

PRINT OR TYPE ONLY

OWNER Paul Kibler ADDRESS AT WELL LOCATION 1740 Catalpa  
Reno, Nevada 89511  
 Mailing Address 1740 Catalpa  
Reno, Nevada 89511  
 2. LOCATION SE 1/4 SW 1/4 Sec. 1 T. 18N N/S R. 19 E Washoe County  
 PERMIT NO. 3966 040 611 06 Lot 10, Lakeside Meadows #3  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
YELLOW CLAY		131	138	7
YELLOW SAND		138	141	3
CLAY/GRAVEL & SAND LENSES		141	230	89
SAND & GRAVEL		230	260	30
BOULDERS & CLAY		260	268	8
CLAY		268	288	20

*Deepening of log # 29869*

DEC -4 AM:33  
90  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter hole 6 5/8 inches Total depth 132 281 feet  
 Casing record 5" to 281  
 Weight per foot 10.79 Thickness 188  

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>132</u> feet
<u>5</u> inches	<u>0</u> feet	<u>281</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation FACTORY PERF  
 Size perforation \_\_\_\_\_  
 From 228 feet to 268 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11-15-90, 19\_\_\_\_  
 Date completed 11-16-90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>91</u>	<u>91</u>		
<u>AIR BLOWN @ 50 GPM</u>			

JUN 28 AM 11:30  
STATE ENGINEERS OFFICE

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 23.5 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Co. Contractor  
 Address P.O. Box 888 Fallon, Nev 89406 Contractor  
 Nevada contractor's license number 11752  
 Nevada contractor's drillers number 772  
 Nevada driller's license number 772 Actual Driller  
 Signed [Signature] Contractor  
 Date 11-24-90