WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44300
Permit No.
Basin Co-87

NOTICE OF INTENT NO. 19104

1. OWNER F.G. Curti Granite Construction
MAILING ADDRESS P.O. Box 2087
Sparks, NV 89432

ADDRESS AT WELL LOCATION
1 mile West of Hwy 395 & 1 mile North of Mt. Rose Hwy.

2. LOCATION NWSE ¼ SWSE ¼ Sec. 2120 T. 18 N/S R. 20 E. Washoe County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
This well was perforated with air activated in hole tool with 4 rows of perforations from 0-77'				
Tremie pipe installed to the bottom & pumped with pure neat cement.				

Date started March 1, 19 94
Date completed March 2, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	0 Feet	77 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.02	.250	0	77

Perforations:
Type perforation Holte air perforator
Size perforation 1 1/2 X 1/4
From 0 feet to 77 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 77'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed C. E. Epler
By driller performing actual drilling on site or contractor

Date 4-8-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627