

OFFICE USE ONLY  
 Log No. 44304  
 Permit No. \_\_\_\_\_  
 Basin. 087

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17561  
 Catelius Corp.

1. Consultant: ERM-West, Inc. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 OWNER \_\_\_\_\_  
 MAILING ADDRESS 2001 P. Street, Suite 200 1235 Glendale Ave.  
Sacramento, CA 95814-5213 Sparks, NV.  
 2. LOCATION SW 1/4 NE 1/4 Sec. 8 T 19N N/S R. 20 E Washoe County  
 PERMIT NO. M/O#Pending 392 MW#1 Sparks, NV. Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	1/2	1/2
Clay, gravel mix		1/2	2 1/2	2
Large boulder-up to 12" dia.		2 1/2	4	1 1/2
Clay, dark gray, moist		4	11	7
Gravel, cobbles to sand		11	25	14
Sand, fine grain to coarse, rounded to angular, heaving, unable to keep hole open past 23 feet.		11	27	16

8. WELL CONSTRUCTION  
 Depth Drilled 27 Feet Depth Cased 22.5 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 5/16 Inches To 27 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		sch 40	0	22.5
4" PVC slip cap				
4" PVC Security cap				

 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 0.020 x 1 1/2 x 6 rows  
 From 9.5 feet to 22.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5.5  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Bentonite: 2  Yes  No  
 Gravel Packed:  Yes  No  
 From 7.5 feet to 22.5 feet

9. WATER LEVEL  
 Static water level 12.51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 4-30-91, 19\_\_\_\_\_  
 Date completed 4-30-91, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NV 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board.  
 Nevada driller's license number 908  
 issued by the Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date April 7, 1994