WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44308
Permit No.
Basin 6-89

NOTICE OF INTENT NO. 26675

1. OWNER LIGHTNING W GOLF COURSE
MAILING ADDRESS 7300 FRANKTOWN RD
CARSON CITY, NV 89704
ADDRESS AT WELL LOCATION CORRAL WELL
SE OF BIG BARN

2. LOCATION NE ¼ SE ¼ Sec. 22 T. 16 N/S R. 19 E. WASHOE County
PERMIT NO. 23287/20648 (Issued by Water Resources) | 055-020-61 (Parcel No.) | GOLF COURSE (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SET UP RIG OVER EXISTING 12" WELL				
RUN SCRUBBER BRUSH FROM GL TO 543'				
BALE HOLE TO 553'				
KNIFE PERFORATE TOP 100' OF WELL CASING — EXTENSIVELY!				
INSTALL 90' OF 8⅝ x ¼ WALL DOUBLE PERFORATED STEEL CASING FROM 300' TO 390', CAPPED WITH SHALE TRAP ON VERY BOTTOM. INSTALL WIREWRAP SCREEN (.080), 8 INCH ID, FROM 120' TO 300'.				
INSTALL BLANK, 8⅝ x ¼ WALL STEEL CASING FROM +2' TO 120'				
GRAVEL PACK WITH ⅛ x ¼ 'AUBURN' GRAVEL FROM 390' UP TO 100 FT				
PUMP 4 YDS OF CONCRETE GROUT FROM 100 FT UP TO 20 FT PUMP 3 YDS OF CEMENT (NEAT) FROM 20 FT TO THE GL.				
BLOW CLEAN				

Date started 3/17, 1994
Date completed 3/25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+	?	6

'94 APR 18 STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled — Feet Depth Cased — Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	—	¼	+2	120
"	—	SCREEN	120	300
"	—	¼	300	390

Perforations:
Type perforation SAWCUT / SCREEN
Size perforation 3 x 3/32 (.080)
From 300 feet to 390 feet
From feet to feet
From 120 feet to 300 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 390 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature COLD °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CREEK RD (Contractor)
CARSON CITY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Leisch (By driller performing actual drilling on site or contractor)
Date 4/11/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627