WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44317
Permit No.
Basin 07-92b

NOTICE OF INTENT NO. 21622

1. OWNER: IMIATZ AMED
MAILING ADDRESS: 3885 Flower Street, Reno, NV 89506
ADDRESS AT WELL LOCATION: 3550 Golden Valley Road, Reno, NV 89506

2. LOCATION: NE ¼ NE ¼ Sec. 14 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 88-512-29 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Tight brown clay		2	6	4
Soft brown sandy clay		6	15	9
Soft purple clay		15	22	7
Soft dark brown clay		22	29	7
Hard gray rock		29	35	6
Rock broken & fractured		35	51	16
Soft zone, rock		51	53	2
Med. hard rock, tan		53	71	18
Soft rock, brown		71	88	17
Med rock, tan		88	96	8
Med rock, gray		96	114	18
Med rock, purple		114	116	2
Fractured rock, gray	X	116	131	15

Date started 7-6-92, 19
Date completed 7-7-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 131 Feet Depth Cased 131 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	131 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	131

Perforations:
Type perforation: factory sawed slot
Size perforation: 3/32 x 3 x 5 around
From 91 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 131 feet

9. WATER LEVEL
Static water level 66.8 feet below land surface
Artesian flow 28 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Wayne Drilling, Inc.
Address (Contractor): P.O. Box 12370, Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board: 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908
Signed (By driller performing actual drilling on site or contractor)
Date July 10, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627