

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24765

1. OWNER Eagle Ranch ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 12241 Pioneer Way 12241 Pioneer Way Fallon
Fallon, NV 89406
 2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 31 T. 19 N S R. 27 E. Churchill County
 PERMIT NO. 35794-48420-21 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Casing was perforated with 10" diameter air activated in hole perforator.				
Six rows of perforations at the following intervals:				
0 - 145'				
184' - 205'				
223' - 285'				
317' - 334'				
Tremie pipe installed to bottom & circulated with 70 viscosity 9 lb. mud to surface.				
Cement catcher installed at 50' level and pumped to surface with pure neat cement.				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	0	356
_____	_____	_____	_____	_____

Perforations:
 Type perforation Holte air perforator
 Size perforation 1 1/2 X 1/8

From	feet to	feet
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Surface Seal: Yes No Seal Type: Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started March 10, 1994
 Date completed March 11, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
 Signed C. P. Epler
 By driller performing actual drilling on site or contractor
 Date 4-8-94