

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 44324
 Permit No. 102
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24660

1. OWNER Kirk White ADDRESS AT WELL LOCATION 4215 Aspen Silver Springs, NV 89429
 MAILING ADDRESS 11625 Wild Flower Rd Silver Springs, NV 89429
 2. LOCATION NE 1/4 NE 1/4 Sec. 35 T. 18 N. S. R. 24 E Lyon County
 PERMIT NO. 15-211-43 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------------|--------------|------|-----|------------|
| surface soil | | 0 | 3 | 3 |
| gravel and sand | | 3 | 25 | 22 |
| brown clay + sand + gravel | | 25 | 75 | 50 |
| sand + gravel | | 75 | 105 | 30 |
| sand + gravel + cobbles | X | 105 | 151 | 46 |

8. WELL CONSTRUCTION
 Depth Drilled 151 Feet Depth Cased 151 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 151
105/8 Inches 0 Feet 151 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>65/8</u> | | <u>.188</u> | <u>+1</u> | <u>151</u> |

Perforations:
 Type perforation Mill
 Size perforation 1/8 x 3
 From 131 feet to 151 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 151 feet

9. WATER LEVEL
 Static water level 24 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 4/10 1994
 Date completed 4/12 1994

7. WELL TEST DATA

| TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
|---|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| <u>18</u> | <u>6</u> | <u>2</u> | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ACE Drilling & Dev. Contractor
 Address P.O. Box 668 Contractor
Silver Springs, NV 89429
 Nevada contractor's license number 14299
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 726
 Division of Water Resources, the on-site driller.
 Signed H.J. Smith
 By driller performing actual drilling on site or contractor
 Date 4/21/94