



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24581

1. OWNER WESTWINDS CONST. ADDRESS AT WELL LOCATION 1758 SOLITUDE
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NE 1/4 NE 1/4 Sec 2 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 23-480-44 WILDFLOWER Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/ GRAVEL		0	7	7
CEMENTED GRAVEL		7	28	21
SANDY CLAY w/ GRAVEL		28	54	26
SANDY CLAY		54	59	5
SANDY CLAY w/ GRAVEL		59	104	45
SANDY CLAY		104	124	20
SANDY CLAY w/ GRAVEL		124	142	18
CLAY		142	146	4
SANDY CLAY w/ GRAVEL		146	162	16
CLAY		162	179	17
SANDY CLAY		179	197	18
SANDY CLAY w/ GRAVEL		197	222	25
CEMENTED GRAVEL	✓	222	240	18

94 APR 18 P 1:31
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 240
10 5/8 Inches. Feet. Feet
 Inches. Feet. Feet
 Inches. Feet. Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	240

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 4-5, 1994
 Date completed 4-13, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Paul J. Mooney
 By driller performing actual drilling on site Contractor
 Date 4-14-94