

OFFICE USE ONLY
 Log No. 44342
 Permit No. 1
 Basin. 8-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24582

1. OWNER WESTWINDS CONSTRUCTION ADDRESS AT WELL LOCATION EAST VALLEY + TOLER
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NE 1/4 NE 1/4 Sec. 2 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 23-480-47 Parcel No. WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other...MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	5	5
SANDY CLAY w/GRAVEL		5	13	8
CEMENTED GRAVEL		13	28	15
SANDY CLAY		28	49	21
CLAY		49	57	8
SANDY CLAY w/GRAVEL		57	77	20
CLAY		77	82	5
SANDY CLAY w/GRAVEL		82	148	66
CLAY		148	155	7
SANDY CLAY w/GRAVEL		155	186	31
CLAY		186	194	8
SANDY CLAY w/GRAVEL		194	197	3
CEMENTED GRAVEL		197	208	11
CLAY		208	216	8
CEMENTED GRAVEL	✓	216	227	11
SANDY CLAY w/GRAVEL		227	233	6
SAND	✓	233	237	4
SANDY CLAY		237	240	3

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 240
105/8 Inches Feet
 _____ Inches Feet
 _____ Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 210 feet to 230 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 3-14, 1994
 Date completed 3-18, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
GARDNERVILLE, NV 89410
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Moore
 By driller performing actual drilling on site or contractor
 Date 3-18-94