WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44343
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 24592

1. OWNER RAYMOND BROWN
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 805 FRED'S ST GARDNERVILLE

2. LOCATION SE ¼ SW ¼ Sec. 17 T. 12 N/S R. 21 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 35-170-13 (Parcel No.) PINE NUT (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Sandy Clay some gravel		3	130	127
Grey Sandy clay		130	235	105
Brown Sandy clay		235	265	30
Grey Sandy clay some gravel		265	305	40
Grey clay		305	362	57
Grey clay w/ some gravel		362	388	26
Grey Sandy clay		388	401	13
Grey Sandy clay w/ short strks sand	✓	401	440	39
Grey Sandy clay		440	451	11
Grey Sandy clay w/ short strks course sand	✓	451	491	40
Grey clay		491	500	9

'94 APR 18 P1:34
STATE ENGINEERS OFFICE

T.C. every 10' 400'-440

Date started 3-7, 1994
Date completed 3-18, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	12+		8

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	500 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	500

Perforations:
Type perforation Factory Slotted / T.C.
Size perforation 3 x 3/32
From 450 feet to 490 feet
From T.C. 400 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 362 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Phinnell (By driller performing actual drilling on site or contractor)
Date 3-18-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627