

OFFICE USE ONLY
 Log No. 44345
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24597

1. OWNER GUS SCHWARTZ ADDRESS AT WELL LOCATION 211 WOODY'S PL
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SW 1/4 SW 1/4 Sec. 34 T. 13 N. R. 19 E. DOUGLAS County
 PERMIT NO. 19-340-20 FOOTMILL Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand w/ DG</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>DG</u>		<u>18</u>	<u>41</u>	
<u>Sandy clay</u>		<u>41</u>	<u>45</u>	
<u>DG w/ short sandy streaks</u>	<u>XX</u>	<u>45</u>	<u>135</u>	

8. WELL CONSTRUCTION

Depth Drilled 0 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 0 Feet 135 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>135</u>

Perforations:
 Type perforation Factory slotted
 Size perforation 3 x 3/32
 From 115 feet to 135 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 135 feet

9. WATER LEVEL

Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started 4-11, 1994
 Date completed 4-12, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>1</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed Jerald W. Phinnell
 By driller performing actual drilling on site or contractor

Date 4-12-94