WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44347
Permit No.
Basin 107

NOTICE OF INTENT NO. 25467

1. OWNER ROSEMARY CONLON
MAILING ADDRESS 514 Hwy 338
WELLINGTON NV 89444

ADDRESS AT WELL LOCATION 514 HWY 338
WELLINGTON NV 89444

2. LOCATION NW ¼ NE ¼ Sec. 20 T. 10 N/S R. 24 E LYON County
PERMIT NO. Issued by Water Resources | Parcel No. 10 741 21 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL SMALL ROCK | | 0 | 25 | |
| GRAVEL LARG | | 25 | 80 | |
| BOLDERS - HARD ROCK | | 80 | 120 | |
| GRAVE W BROWN CLAY | | 120 | 215 | |
| GRAVEL | WB | 215 | 276 | |

Date started 4 8, 19 94
Date completed 4 13, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | 170 | 4½ |

8. WELL CONSTRUCTION
Depth Drilled 276 Feet Depth Cased 276 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 12½ | 0 | 276 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | | 188 | 0 | 276 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY
Size perforation 3/32 x 3
From 236 feet to 276 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From 0 feet to 100 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ED MILLER (Contractor)
Address PO BOX 92 SMITH NV 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 26166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/14/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627