WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 61880
Permit No.
Basin 033 AT
NOTICE OF INTENT NO. 18027

PRINT OR TYPE ONLY

1. OWNER Key Farms
MAILING ADDRESS Orovada NV
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 33 T. 43 N/S R. 37 E. Humboldt County
PERMIT NO. 29712/29723 ? (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil w/s small gravel		0	75	75
DG/w/s clay		75	125	50
~~Gravel~~ Gravel		125	140	15
DG w/s clay		140	155	15
Gravel w/s clay streaks		155	270	115
DG & gravel		270	345	75
clean Gravel		345	375	30
Clay		375	420	45
Gravel w/s clay streaks		420	505	85
Clay w/s gravel		505	525	20
Gravel w/ Hard Rock		525	600	75

STATE ENGINEERS OFFICE
'94 MAY 12 A10:19

Date started 3-26, 1994
Date completed 4-12, 1994

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	3000	180	2

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 26 inches Total depth 600 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
16 inches	+1 feet	600 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 600 feet

Perforations:
Type perforation Factory Slots
Size perforation 3/16 X 3 in
From 200 feet to 600 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Brinkerhoff (Contractor)
Address 3040 Callahan Winnemucca NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada contractor's driller's number issued by the Division of Water Resources 1161
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161
Signed ..... (By driller performing actual drilling on site or contractor)
Date 5-9-94

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627