

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24347

1. OWNER USGS - Kiley #4c ADDRESS AT WELL LOCATION 7000 Pyramid Highway  
MAILING ADDRESS 333 W. Nye Ln Sparks NV  
Carson City NV 89706  
2. LOCATION NW 1/4 SE 15 T. 20 S. R. 20 E Washoe County  
PERMIT NO. M/0-770 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravelly sandy silt</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Silty sandy gravel</u>		<u>2</u>	<u>3</u>	<u>1</u>
<u>Gravel</u>	<u>X</u>	<u>3</u>	<u>3 1/2</u>	<u>1/2</u>
<u>Sand.</u>	<u>X</u>	<u>3 1/2</u>	<u>7</u>	<u>3 1/2</u>

194 MAY 12 AM 10:21  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 7 Feet Depth Cased 7 Feet

HOLE DIAMETER (BIT SIZE)  
From 0 To 7  
4 3/4 Inches 0 Feet 7 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch -40</u>	<u>0</u>	<u>5</u>

Perforations:  
Type perforation Slot  
Size perforation .020  
From 5 feet to 7 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 3 feet  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 3 feet to 7 feet

9. WATER LEVEL  
Static water level 4.87 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 4/25, 1994  
Date completed 4/25, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Armando R. Robledo, USGS Contractor  
Address 333 W. Nye Ln Contractor  
Carson City NV 89706  
Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources to the on-site driller 1859 FP  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 5/12/94