REPORT NO. 94.41

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 44418
PERMIT NO.
BASIN 085

NOTICE OF INTENT NO. 26110

OWNER Rick & Terry Humphry
MAILING ADDRESS 13040 Welcome Way Reno, Nv

ADDRESS OF WELL 2130 Sienna Ct
Sparks, Nv 89436

2. WELL LOCATION SW 1/4 NW 1/4 SEC. 31 T 21N R 21 E Washoe COUNTY

PERMIT NO. ____ PARCEL NO 076-390-23 SUBDIVISION NAME Spanish Springs

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
DG, cobbles & boulders w/brown clay		0	7	7
Brn clay w/white, grn, yellow, brn,		7		
orange and red sands & gravels		7	146	139
Same sands & gravels w/lt grn clay		146	184	38
Green, broken volcanic rock		184	196	12
Red clay w/red volcanic rock		196	218	22
Green, fractured, volcanic rock		218	225	7
Brn, yellow, orange, red & grn volcanic		225		
gravels with brown clay		225	262	37
Orange clay w/orange, brn & yellow		262		
volcanic gravels		262	294	32
Broken, purple & grn volcanic rock w/		294		
traces of brown clay		294	345	51
Purple & green rock		345	375	30
Red & orange volcanic cinders		375	380	5

Notes :

'94 JUN -1 A10:53
RECEIVED
STATE ENGINEERS OFFICE

Date Started 5/20/94 Date Completed 5/23/94

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

	GPM	DRAWDOWN	TIME (HRS)
	20+		2

8. WELL CONSTRUCTION

Depth Drilled 380 Depth Cased 380

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 62 Feet
8 1/2 Inches 62 Feet 380 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	380

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 360 Feet to 380 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 54'
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 54 Feet to 380 Feet

9. WATER LEVEL

Static Water Level 160 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality ____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1511

Signed Roger Thrift
By driller performing actual drilling on site or contractor

Dated 5/26/94