WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44436
Permit No.
Basin 87

NOTICE OF INTENT NO. 2182

1. OWNER US Geological Survey WRD
MAILING ADDRESS 333 W Nye Lane
Carson City Nv 89706 (702) 887-7600

ADDRESS AT WELL LOCATION Neil Road at Nutmeg Drive

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 19 ☒ S R. 20 E. Washoe County

PERMIT NO. MO-769 (Issued by Water Resources) | Parcel No. | Neil Road Park Well (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger Rig

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Granite		0	1	1
Clay, moist, yellowish brown		1	5	4
Sandy Clay, moist, grayish orange		5	8	3
Water Return	8'			
Clayey Sand, Saturated		8	15	7

Date started April 12, 1994
Date completed April 12, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/2 Inches	0 Feet	15 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC (Sch. 40)		0	15
	Screw Type Joints			

Perforations:
Type perforation Slot Type
Size perforation 0.020'
From 10 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0 TO 5'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 9 feet to 15 feet

9. WATER LEVEL
Static water level 6.10 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality Unknown as yet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Robert N. Pennington USGS WRD (Contractor)
Address 333 W. Nye Lane (Contractor)
Carson City Nv 89706 (887-7600)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-1857
Signed Robert N. Pennington (By driller performing actual drilling on site or contractor)
Date April 20, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627