WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44434
Permit No.
Basin 4-059

NOTICE OF INTENT NO. 26423

1. OWNER Echo Bay Minerals
MAILING ADDRESS P.O Box 1658
Battle Mtn. Nevada 89820

ADDRESS AT WELL LOCATION McCoy mine

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 29 N/S R. 43 E. Lander County

PERMIT NO. m/o - 189A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Gravel		0	160	
	x	90	140	50

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 1/4 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 in	PVC	sch 80	0	160

Perforations:
Type perforation slotted
Size perforation .010
From 130 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 90 feet to 160 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLund Drilling Inc (Contractor)
Address P.O. Box 2786 (Contractor)
Elko NV. 89803
Nevada contractor's license number issued by the State Contractor's Board #0030923
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1759
Signed Tom Kools (By driller performing actual drilling on site or contractor)
Date April 20, 1994

Date started March 20, 1994
Date completed March 20, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

'94 MAY -2 P2:34
STATE ENGINEER

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627