

OFFICE USE ONLY  
 Log No. 44-189  
 Permit No. 1  
 Basin 41-019

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26421

1. OWNER Echo Bay Minerals ADDRESS AT WELL LOCATION McCoy mine  
 MAILING ADDRESS P.O. Box 1658  
BATTLE Mtn NEVADA 89820  
 2. LOCATION SW 1/4 SW 1/4 Sec. 18 T. 29 N/S R. 43 E Lander County  
 PERMIT NO. M10-189A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY GRAVEL		0	90	
LIMESTONE		90	440	
FRACTURED LIMESTONE	X	200	210	

8. WELL CONSTRUCTION  
 Depth Drilled 440 Feet Depth Cased 440 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
8 1/4 Inches 0 Feet 100 Feet  
6 Inches 100 Feet 440 Feet  
 Inches Feet Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>SCH 80</u>	<u>0</u>	<u>440</u>

Perforations:  
 Type perforation 1.010 slotted  
 Size perforation 1.010  
 From Blank 0 feet to 400 feet  
 From SCREEN 400 feet to 420 feet  
 From Blank 420 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 200 feet to 440 feet

94 MAY -2 2:34  
 STATE ENGINEER

Date started MARCH 20, 1994  
 Date completed MARCH 21, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>5-10 gal</u>	<u>per minute</u>	<u>At depth 440</u>

9. WATER LEVEL  
 Static water level 19 1/2 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 101.1 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EKLUND Drilling Company Contractor  
 Address P.O. Box 2786 Contractor  
LIKO NV 89807 Contractor  
 Nevada contractor's license number 0030823  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1759  
 Division of Water Resources, the on-site driller.  
 Signed TOM KOUSS  
 By driller performing actual drilling on site or contractor  
 Date April 20, 1994