WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44442
Permit No.
Basin 083

NOTICE OF INTENT NO. 24899

1. OWNER Robert Rubinski
MAILING ADDRESS PO Box 475 Reno Nev 89504
ADDRESS AT WELL LOCATION 1880 Castle Peak Rd Virginia City, Nev

2. LOCATION NW ¼ NE ¼ Sec. 30 T. 18 N/S R. 21 E. Storey County
PERMIT NO. (Issued by Water Resources) Parcel No. VC Highlands (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Top Soil		0	4	4'
Yellow claystone		4	25	21
soft Black Rock	58'	25	75	50
Hard Black Rock		75	150	75
Blue Shale fractured	*	150	200	

'94 MAY 17 A11:02
STATE ENGINEER'S OFFICE

Date started April 18, 1994
Date completed April 25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
8 1/2 Inches		50 Feet	100 Feet
7 7/8 Inches		100 Feet	200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	200

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From ... feet to ... feet
From 160 feet to 180 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow ... G.P.M. ... P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling (Contractor)
Address P.O. Box 1345 (Contractor)
Dayton, Nev
Nevada contractor's license number issued by the State Contractor's Board 4739 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
Signed Lee A. Enloe (By driller performing actual drilling on site or contractor)
Date April 28 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627