

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26299

1. OWNER ERIC BROOKE ADDRESS AT WELL LOCATION 2653 B Brookmeadow  
 MAILING ADDRESS 2509 Garfield Ct Sparks 89431  
 2. LOCATION N.E. 1/4 SW 1/4 Sec 2 T. 17 N S R. 181E Washoe County  
 PERMIT NO. 045-472-33 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	36	36
Clay, Sandy		36	64	28
Clay & Small Gravel		64	91	27
Conglomerate		91	122	31
Gravel, loose		122	130	8
Clay, Sandy		130	146	16
Do. Gr.		146	220	74

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 100 Feet  
9 3/4 Inches 100 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.97</u>	<u>0.189</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation factory mill slot  
 Size perforation 3/32  
 From 140 feet to 160 feet  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 220 feet

'94 JUN -3 410:31  
 STATE ENGINEER'S OFFICE

Date started 5-14, 1994  
 Date completed 5-18, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>63</u>	<u>---</u>	<u>5</u>
<u>Pumping level 130</u>		

9. WATER LEVEL  
 Static water level 98 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Mexican Drilling Contractor  
 Address 2790 Pioneer Drive Reno, Nevada 89509 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 14170  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed Steve Marko  
 By driller performing actual drilling on site or contractor  
 Date 6/2/94