WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44453
Permit No.
Basin 087

NOTICE OF INTENT NO. 23922

1. OWNER Donald & Sally Keytner
MAILING ADDRESS 3450 Quilic Reno NV
ADDRESS AT WELL LOCATION 3450 Quilic Reno Nevada

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 18 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 040-730-09 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Boulders		0	59	59
Clay, brown, Sandy		59	112	53
Gravel to ½"		112	123	11
Clay, brown, Sandy		123	140	17
Sand, Coarse, Compacted		140	200	60

'94 MAY 18 AM 11 57
STATE ENGINEER'S OFFICE

Date started 4-20, 1994
Date completed 4-25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
89	—	2
Pumping Level 75'		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	100 Feet
9⅞ Inches		100 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.97	0.188	0	200

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling (Contractor)
Address 2270 Pioneer Drive (Contractor)
Reno, Nevada
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/17/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627