

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 44476
 Permit No. _____
 Basin 102

NOTICE OF INTENT NO. 24665

1. OWNER Kirk White ADDRESS AT WELL LOCATION 3510 River Valley Rd. Silver Springs, NV 89429
 MAILING ADDRESS 11625 Wild Flower Rd. Silver Springs, NV 89429
 2. LOCATION NE 1/4 NE 1/4 Sec 21 T 17 S R 24 E Lyon County
 PERMIT NO. 17-511-18 Parcel No. _____ Subdivision Name River Valley View Estates
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>fine to coarse sand</u>		<u>0</u>	<u>32</u>	<u>32</u>
<u>gray clay</u>		<u>32</u>	<u>46</u>	<u>14</u>
<u>brown clay</u>		<u>46</u>	<u>62</u>	<u>16</u>
<u>fine to coarse sand</u>	<u>X</u>	<u>62</u>	<u>100</u>	<u>38</u>

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 To 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>100</u>

Perforations:
 Type perforation Mill
 Size perforation 1/2 x 3
 From 80 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 29 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 5/7 1994
 Date completed 5/8 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>6</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ACE Drilling & Dev.
 Address P.O. Box 668 Silver Springs, NV 89429
 Nevada contractor's license number 14299 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
 Signed H. L. [Signature]
 By driller performing actual drilling on site or contractor
 Date 5/9/94