WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44493
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 26754

1. OWNER Eugene Wood
MAILING ADDRESS 230 Willey Ave. Dayton NV
ADDRESS AT WELL LOCATION 230 Willey Ave Dayton, Nevada

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 17 N/S R. 22 E. Storey County
PERMIT NO. 03-294-13 (Issued by Water Resources) Parcel No. 68 Subdivision Name Marktwain

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil, Boulders		0	5	5
Soil, Boulders		5	128	123
Clay		128	154	26
Black Shale, Clay Streaks		154	185	31
Clay		185	210	25
Black Shale		210	233	13
Black Shale, Clay Streaks		233	356	23
Andesite		356	440	84
Fractured broken andesite		(415	440)	25

Hole Started by Driller No. 1877
Well Completed by Driller No. 1876
200' to 440'

RECEIVED MAY 23 '94 STATE ENGINEERS OFFICE

Date started 4/22/94, 19
Date completed 5/2/94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10-15		12 hrs

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 441 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	60
8 3/4	60	358
6	358	440

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	+1	358
4 3/4		2.50	355	440

Perforations:
Type perforation Torch Perf / Air Perf
Size perforation 3/16 x 12 x 4 rows perf
From 300 feet to 340 air perf feet
From 340 feet to 360 Torch feet
From 426 feet to 440 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 358 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO. 599 (Contractor)
Ss. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Daniel Leach (By driller performing actual drilling on site or contractor)
Date 5/3/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627