

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 44485  
 Permit No. \_\_\_\_\_  
 Basin 103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 26811

1. OWNER Rolland Ninas ADDRESS AT WELL LOCATION 814 Lafond Ave Dayton NV. 89721  
 MAILING ADDRESS 814 Lafond Ave Dayton NV. 89721  
 2. LOCATION SE 1/4 SE 1/4 Sec. 20 T 17 N S R 22 E Storey County  
 PERMIT NO. 23-312-08 Parcel No. \_\_\_\_\_ Subdivision Name Mark Twain Estates

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sands		0	6	6
Broken Obsidian Volcanic Gravel		6	74	68
Brown Clay/Zone		74	134	60
Volcanic Gravel w/ Inbedded Clays		134	168	34
Large Volcanic Gravel	XXX	168	220	52

8. WELL CONSTRUCTION  
 Depth Drilled 220' Feet Depth Cased 220' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1 1/4 Inches 0 Feet 5.5 Feet  
10 3/4 Inches 5.5 Feet 220' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3x3/32  
 From 180 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 65 feet to 220 feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20+ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 5-16-1994  
 Date completed 5-19-1994

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>25</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
**A & H PUMP CO.**  
 Name 5551 Hwy. 50 East #1  
Carson City, Nevada 897  
 Address 33-0459 885-1889  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael L. Haek  
 By driller performing actual drilling on site or contractor  
 Date 5-19-94

'94 MAY 20 PM 4:27  
 RECEIVED  
 STATE ENGINEERS OFFICE