WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44489
Permit No.
Basin 0124

NOTICE OF INTENT NO. 23391

1. OWNER ANNA RAMSEY
MAILING ADDRESS 11300 Carlsbad
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SE ¼ Sec. 24 T 21N N/S R 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-212-06 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Sandy brown clay		1	17	16
Brown clay		17	49	32
Dark brown clay		49	60	11
Granite sand		60	63	3
Brown sandy clay		63	101	39
Brown clay		101	119	18
Soft zone	X	119	124	25
Brown clay		124	148	24
Soft zone	X	148	156	8
Brown sandy clay		156	169	13
Gray clay		169	173	4
Soft zone	X	173	186	13
Brown sandy clay		186	190	6

'94 MAY 23 P 4:12
STATE ENGINEER'S OFFICE

Date started 5-16-94, 19
Date completed 5-17-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	190 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	190

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 145 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 190 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. 16 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 19, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627