WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 44475
Permit No.
Basin 090B T
NOTICE OF INTENT NO. 23123

1. OWNER Patricia Moore
MAILING ADDRESS 2690 Margaret Dr Reno, Nevada
ADDRESS AT WELL LOCATION 2690 Margaret Drive Reno, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 10 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 088-093-09 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Rock dark gray Fractured | ✓ | 113 | 195 | 82 |
| Granite, fractured | ✓ | 195 | 273 | 78 |

RECEIVED MAY 18 1994 STATE ENGINEER'S OFFICE

Date started 4/26/1994
Date completed 4/28/1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 35 | | 2 |
| pumping level 125 | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 8 | 113 | 273 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.97 | 1.88 | 9.5 | 255 |
| 5 | 9.66 | 1.88 | 253 | 273 |

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32
From 175 feet to 195 feet
From 235 feet to 273 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling (Contractor)
Address 2290 Pioneer Drive (Contractor) Reno, Nevada
Nevada contractor's license number issued by the State Contractor's Board 14720
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/17/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (D)-627