WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44498
Permit No.
Basin 1051

NOTICE OF INTENT NO. 24926

1. OWNER RICHARD BROWN
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1027 VERDE WAY GARDNERVILLE

2. LOCATION NW ¼ SW ¼ Sec. 17 T. 12 N R. 20 E. DOUGLAS County
PERMIT NO. — Issued by Water Resources
27-080-03 Parcel No.
CHAMBER'S FIELD Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cobbles w/sandy clay		0	43	43
Sandy clay		43	47	3
cobbles gravel w/sandy clay		47	82	35
Sandy clay		82	85	3
gravel w/sandy clay strks		85	119	34
Sandy clay		119	123	4
gravel w sandy clay strks		123	140	17

RECEIVED 94 MAY 23 P 4:13 STATE ENGINEERS OFFICE

Date started 4-13, 1994
Date completed 4-18, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	25+		1.5

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	140

Perforations:
Type perforation Factory Slotted
Size perforation 3x 3/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100' feet to 140' feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Thurnell (By driller performing actual drilling on site or contractor)
Date 4-19-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627