WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44500
Permit No.
Basin 105

NOTICE OF INTENT NO. 26672

1. OWNER JOE HEFLIN
MAILING ADDRESS BOX 1618
GARDNERVILLE NV 89410

ADDRESS AT WELL LOCATION 2600 OLD RANCH RD
GARDNERVILLE NV 89410

2. LOCATION SW ¼ SW ¼ Sec. 10 T. 12 N/S R. 21 E. DOUGLAS County
PERMIT NO. (Issued by Water Resources) 35-010-30 (Parcel No.) NONE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HILLSIDE AL		0	6	6
ALTERED AL W LT BRWN CLAY		6	59	53
MOSTLY CLAYER AL		59	135	76
MORE ROCK, LESS CLAY		135	160	25
VERY STICKY, LT BRWN CLAY, MINOR ROCK FRAGS		160	240	80
MONTMORILLONITE CLAY? SWELLS, STICKY, LT BROWN		240	310	70
		310	380	70
PENETRATED A FAULT ZONE,	X	380	432	52
UNDERLYING BED ROCK IS A FRACTURED GREY, HARD, GRANODIORITE OR RHYOLITE				

JUN -6 P2:44
RECEIVED STATE ENGINEERS OFFICE

Date started 2/7, 1994
Date completed 2/11, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		4 HRS

8. WELL CONSTRUCTION
Depth Drilled 432 Feet Depth Cased 432 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	100
11	100	432

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	13	.188	+2	432

Perforations:
Type perforation SAWCUT
Size perforation 3X 3/32
From 352 feet to 432 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 432 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow NO G.P.M. ? P.S.I.
Water temperature COLD °F Quality ?

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC. (Contractor)
Address 75 LEWERS CREEK RD (Contractor)
CARSON CITY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisch (By driller performing actual drilling on site or contractor)
Date 4/4/94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627