

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29328

1. OWNER Beech Mandeville ADDRESS AT WELL LOCATION 1708 Dawn cct
 MAILING ADDRESS PO Box 2646 Minden NV 89423
 2. LOCATION NW 1/4 SW 1/4 Sec 2 T 13 N/S R. 20 E County Douglas
 PERMIT NO. NW SE 23-090-62 Parcel No. _____ Subdivision Name Union Tr.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	10	
COARSE SAND & SOME GRAVEL		10	55	
CLAY & SAND		55	70	
CLAY SAND & GRAVEL		70	110	
CLAY & SAND		110	120	
CLAY SAND & GRAVEL		120	160	
SAND	X	160	180	
CLAY & SAND		180	200	
CLAY		200	215	
SAND	XX	215	240	
CLAY & SAND		240	275	
CLAY SAND & GRAVEL	XX	275	300	

94 MAY 17 10:17
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 300
9 7/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>15 1/2</u>	<u>RP</u>	<u>0</u>	<u>300</u>

Perforations:
 Type perforation Free & Open
 Size perforation 3 x 5 1/2"
 From _____ feet to _____ feet
 From 300 feet to 280 feet
 From 240 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 300 feet to 50 feet

9. WATER LEVEL
 Static water level 155 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1-21, 1994
 Date completed 1-26, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>40-50</u>	<u>~</u>	<u>1 1/2 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Kawhook Drilling Inc. Contractor
 Address PO Box 1359 Minden NV Contractor
 Nevada contractor's license number #021268 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
 Signed Michael Callan
 By driller performing actual drilling on site or contractor
 Date 1-26-94