

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25327

1. OWNER Robert Taylor ADDRESS AT WELL LOCATION 2432 Hospita rd. Minden NV
 MAILING ADDRESS 3527 Windsor wheel cel. China Cal 91710
 2. LOCATION SE 1/4 SE 1/4 Sec 2 T. 13 N/S R. 20 E Douglas County
 PERMIT NO. 23-090-23 Parcel No. 23-090-23 Subdivision Name Senise Pass
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND GRAVEL & ROCKS		0	50	
CLAY SAND & GRAVEL		50	75	
CLAY & SAND		75	85	
CLAY SAND & GRAVEL		85	135	
CLAY & SAND		135	190	
SAND	X	190	205	
CLAY & SAND		205	225	
SAND	XY	225	240	
CLAY		240	265	
CLAY & SAND		265	285	
CLAY SAND & GRAVEL	XY	285	300	

94 MAY 17 AIO 17
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cascd 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>1516</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:
 Type perforation Factory & hand-cut
 Size perforation 3 X 5/16"
 From _____ feet to _____ feet
 From 300 feet to 280 feet
 From 240 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 300 feet to 50 feet

9. WATER LEVEL
 Static water level 185 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1-14 1994
 Date completed 1-20 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>40-50</u>	<u>-</u>	<u>1hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kauchnek Drilling Inc. Contractor
 Address PO Box 1359 Minden NV Contractor
 Nevada contractor's license number #02268 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
 Signed Michael Callan by driller performing actual drilling on site or contractor
 Date 1-20-94