

OFFICE USE ONLY  
 Log No. 44505  
 Permit No. \_\_\_\_\_  
 Basin. 100

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24931

1. OWNER LUIGI VISO ADDRESS AT WELL LOCATION 4255 BOSLER  
 MAILING ADDRESS WELLINGTON, NV WELLINGTON, NV

2. LOCATION Nw 1/4, Nw 1/4 Sec. 13 T. 10 N. R. 22 E. DOUGLAS County  
 PERMIT NO. 37-143-07 TOPAZ RANCH ESTATES Subdivision Name  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard pan		0	3	3
Sand some gravel		3	12	9
gravel w/sandy clay		12	41	29
Sandy clay some gravel		41	65	24
gravel w/ some sandy clay		65	82	17
diorite		82	95	13
Sandy clay some gravel		95	105	10
gravel w/some clay		105	115	10
Sandy clay		115	123	8
diorite	X	123	135	12
Sandy clay		135	140	5
Sharp gravel	X	140	147	7
Sandy clay		147	152	5
diorite w/ clay in fractures	X	152	163	11
diorite fractured	X	163	188	25

'94 MAY 23 P 4:12  
STATE ENGINEERS OF

8. WELL CONSTRUCTION  
 Depth Drilled 0 Feet Depth Cased 188 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches 0 Feet 188 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	

Perforations:  
 Type perforation Factory slotted / To sack cut  
 Size perforation 3 x 3/32  
 From Factory 188 feet to 168 feet  
 From J.C. 168 feet to 128 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50'  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 188 feet

9. WATER LEVEL  
 Static water level 85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 66.5 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDICO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Phinney  
 By driller performing actual drilling on site or contractor  
 Date 5-12-94

Date started 5-4, 1994  
 Date completed 5-11, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>3</u>