WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44530
Permit No.
Basin 108

NOTICE OF INTENT NO. 26615

1. OWNER Peggy Hyde
MAILING ADDRESS Longley Lane
Yerington, NV. 89511

ADDRESS AT WELL LOCATION Longley Lane
Yerington, Nevada 89511

2. LOCATION W1/2 ¼ NE ¼ Sec. 13 T. 12 N/S R. 25 E. Lyon County

PERMIT NO. N/A (Issued by Water Resources) | 04-382-29 (Parcel No.) | Panavista Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Gravels		5	47	42
Hard Granite		47	115	68
Tan Clay with some Granite		115	119	4
Brown Clay		119	126	7
Black shale		126	134	8
Brown Clay		134	146	12
Broken Granite		146	163	17
Broken Granite with Some Counts	✓	163	200	37

'94 MAY 25 AM 11
RECEIVED
STATE ENGINEERS OFFICE

Date started 5-16, 1994
Date completed 5-18, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For Hours And			
Produced about 30 Gallons A min.			

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	100 Feet
8 3/4 Inches	100 Feet	200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	200

Perforations:
Type perforation AIR PerF
Size perforation 1/4 x 6 Rows
From 150 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-100
Placement Method: ☑ Pumped ☐ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc (Contractor)
Address PO Box 579 Silverspring (Contractor)
NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877

Signed Mathew Leach Jr (By driller performing actual drilling on site or contractor)
Date 5/20/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627