

OFFICE USE ONLY  
 Log No. 44531  
 Permit No. \_\_\_\_\_  
 Basin. 108



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20725

1. OWNER Jeff Seldon Midge ADDRESS AT WELL LOCATION Paravista NO. 4  
 MAILING ADDRESS Paravista NO. 4 Yemington, NV. 89447  
 2. LOCATION W 1/4 NE 1/4 Sec. 13 T. 12 N/S R 25 E Lyon County  
 PERMIT NO. N/A 04-384-04 Paravista Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVZ  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Sand And Gravel</u>		<u>2</u>	<u>123</u>	<u>121</u>
<u>Tan Clay</u>		<u>123</u>	<u>183</u>	<u>60</u>
<u>Hard Granite</u>		<u>183</u>	<u>241</u>	<u>58</u>
<u>Hard Granite with some Gravel</u>		<u>241</u>	<u>260</u>	<u>19</u>
<u>Hard Granite</u>		<u>260</u>	<u>280</u>	<u>20</u>

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>100</u>	<u>Feet</u>
<u>8 3/4</u>	<u>100</u>	<u>280</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>71</u>	<u>280</u>

Perforations:  
 Type perforation Turb. Cat  
 Size perforation 1 1/8" Long 4 Rows  
 From 240 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 0-100

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 100 feet to 280 feet

9. WATER LEVEL  
 Static water level 70 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Arch Drilling Inc  
 Address Po Box 599 Silver Springs NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 00318411  
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 1877  
 Signed Matthew Steach  
 By driller performing actual drilling on site or contractor  
 Date 5-14-94

Date started 5-7, 1994  
 Date completed 5-13, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>Developed For 2 Hours And Produced About 755 GPM</u>		

'94 MAY 25 AM 1:00  
 STATE ENGINEERS OFFICE