

DW11

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 44532
Permit No.
Basin 137 B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22322

1. OWNER Round Mountain Gold Corp. ADDRESS AT WELL LOCATION Minesite
MAILING ADDRESS P.O. Box 480 No physical address
Round Mountain, NV. 89045
2. LOCATION SW 1/4 SW 1/4 Sec 19 T. 10. N 8 R 34 E Nye County
PERMIT NO. 59125 T. W. 387 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
	<u>9.55</u>			
<u>Lith Log</u>	<u>9.80</u>			
<u>Attached</u>	<u>12.50</u>			

8. WELL CONSTRUCTION
Depth Drilled 1260 Feet Depth Cased 1260 Feet
HOLE DIAMETER (BIT SIZE)
From To
21.5 Inches 0 Feet 235 Feet
1.5 Inches 235 Feet 1155 Feet
14 3/4 Inches 1155 Feet 1260 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
16 42.05 12.50 0 235
10 3/4 28.04 12.50 +3 1260
Perforations:
Type perforation shutter
Size perforation 1/8 x 3
From 9.55 feet to 11.95 feet
From 12.35 feet to 12.55 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 235' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

Date started 8-16, 1993
Date completed 4-22, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>268</u>	<u>10</u>	<u>8 hrs</u>

9. WATER LEVEL
Static water level 680 feet below land surface
Artesian flow 250 G.P.M. _____ P.S.I.
Water temperature 104 °F Quality Poor
10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Waytek Drilling Co. Contractor
Address 2220 Stowe Dr Contractor
 Reno, NV. 89511
Nevada contractor's license number issued by the State Contractor's Board 025421
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442/1374
Signed Leo Waytek
By driller performing actual drilling on site or contractor
Date 5-9-94