

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25195

1. OWNER Dees Const ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 2782 3621 Quail Run Rd
Minden, Nev Wellington, Nev
2. LOCATION SW 1/4 SW 1/4 Sec 9 T. 10 N/S R 22 E Douglas County
PERMIT NO. 37-630-04 Pleasant Meadows Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay Brown		0	15	15
Heavy gravel & Clay		15	40	25
Course to fine gravel		40	90	50
Fine gravel & sand	*	90	120	30
saturated	60-70			

94 JUN 16 AM 11:13 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
10 5/8 Inches 0 Feet 120 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>120</u>

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From _____ feet to _____ feet
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 100 feet to 120 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Clear

Date started May 20 1994
Date completed May 20 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling Contractor
Address P.O. Box 1345 Contractor
Dayton, Nev
Nevada contractor's license number issued by the State Contractor's Board 4739A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
Signed Joe A. Enloe
By driller performing actual drilling on site or contractor
Date May 23 1994