WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44544
Permit No.
Basin 137B

NOTICE OF INTENT NO. 22328

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain NV 89045

ADDRESS AT WELL LOCATION Minesite
Piezometer site P-2

2. LOCATION SW ¼ SW ¼ Sec. 19 T. 10 N/S R. 43 E. Nye County

PERMIT NO. Waiver MO 671 A
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Piezometer
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Aluv. granite Dominate		0	410	410
Volcanics Tuff Dominated		410	615	205
Lake bed Sediments	—	615	820	205
Bedrock		820	830	10

'94 JUN 28 A10:42
STATE ENGINEER

Date started 6-10, 1994
Date completed 6-13, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 880 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	20 Feet
6 1/4 Inches	20 Feet	880 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.79	.188	+1	20
1"		Sch. 80	+1	840

Perforations:
Type perforation PVC screen
Size perforation .020
From 820 feet to 840 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Enviroplug 50'-810'
Gravel Packed: ☒ Yes ☐ No
From 810 feet to 880 feet

9. WATER LEVEL
Static water level Not Available feet below land surface
Artesian flow At this Time G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Woytek Drilling Co.
Contractor
Address 2220 Stowe Dr
Contractor
Reno NV 89511

Nevada contractor's license number issued by the State Contractor's Board 024521

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442-1374

Signed Les Woytek
By driller performing actual drilling on site or contractor

Date 6-24-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627