

OFFICE USE ONLY  
 Log No. 44547  
 Permit No. \_\_\_\_\_  
 Basin. 107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 25332

1. OWNER Dennis Wills ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 801 \_\_\_\_\_  
Minden, NV 89423 \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec 12 T 11 N/S R 23 E Lion County \_\_\_\_\_  
 PERMIT NO. 10-361-17 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay + Sand		0	27	
clay		27	55	
clay + sand		55	90	
Sand	X	90	105	
Clay Sand + Gavel	XX	105	155	
clay + sand	XX	155	240	

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
9 7/8 Inches 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	7	.188	0	240

Perforations:  
 Type perforation Factory  
 Size perforation 3 x 5/32 mill slot  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 77 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 2/13, 1994  
 Date completed 2/21, 1994

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>Air Lift</u>	<u>+22 Gpm</u>	<u>2 Hrs</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Inc. Contractor  
 Address P.O. Box 1359 Contractor  
Minden, NV 89423  
 Nevada contractor's license number issued by the State Contractor's Board 021268  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1380  
 Signed E. V. Kawchack  
 By driller performing actual drilling on site or contractor  
 Date 2/26/94

'94 JUN 23 AM 12:29  
 STATE ENGINEERS OFFICE