


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 12541

1. OWNER United States Air Force ADDRESS AT WELL LOCATION _____
MAILING ADDRESS Nellis Air Force Base Las Vegas Blvd - Sloan Rd.
North Las Vegas, Nev. 89115

2. LOCATION NE 1/4 NE 1/4 Sec. 4 T. 20 N/S R. 63 E Clark County _____

PERMIT NO. R-1004 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Remediation WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Silt		0	14	14
Calichified Silt		14	19	2
Sandy Silt		19	48	29
Silty Clay		48	68	20
Sandy Silt		68	73	5
Silty Clay		73	121.6	48.6

8. WELL CONSTRUCTION
Depth Drilled 121.6 Feet Depth Cased 121.6 Feet
HOLE DIAMETER (BIT SIZE)
From 15 Inches To 0.125 Feet 121.6 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	SCH 80	AST 480-90	+3	58.1
10"	Sen 40	S.S. Sump	118.1	121.1

Perforations:
Type perforation S. Steel Slotted
Size perforation .020
From 58.1 feet to 118.1 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 53.1 Neat Cement Grout
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
3% Bentonite
Gravel Packed: Yes No
From 53.1 feet to 121.6 feet

9. WATER LEVEL
Static water level 76.85 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 74.5 °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water Development Corp. Contractor
Address 1202 Kentucky Avenue Contractor
Woodland, Ca. 95776
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1368
Signed J. Miller Smith
By driller performing actual drilling on site or contractor
Date _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>12.4</u>	<u>13.49</u>	<u>3</u>

94 MAY 16 P2:38
STATE ENGINEERS OFFICE

RECEIVED
MAY 18 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-10, 19 94
Date completed 1-13, 19 94