

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 44603
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 12529

1. OWNER United States Air Force ADDRESS AT WELL LOCATION Las Vegas Blvd
 MAILING ADDRESS Nellis Air Force Base Near Sloan Rd.
North Las Vegas, Nev

2. LOCATION NE 1/4 NE 1/4 Sec. 3 T. 20 N/S R. 63 E Clark County _____
 PERMIT NO. R-1004 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Remediation WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Silt		0	13	13
Calichified Silt		13	23	10
Sandy Silt		23	30	7
Calichified Silt		30	34	4
Sandy Silt		34	48	14
Silty Clay		48	57	9
Caliche - Pink		57	58	1
Silty Clay		58	73	15
Calichified Silt		73	83	10
Silty Clay		83	88	5
Gravelly Clay		88	121	33

8. WELL CONSTRUCTION
 Depth Drilled 121 Feet Depth Cased 121 Feet
 HOLE DIAMETER (BIT SIZE)
 From 15 Inches To 121 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	SCH 80	AST 480-81	+3	121 58

Perforations:
 Type perforation 10" Stainless Steel Wire Wrap
 Size perforation .020 Casing
 From 58 feet to 121 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
3% Benonite
 Gravel Packed: Yes No
 From 55 feet to 121 feet

9. WATER LEVEL
 Static water level 78.57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.2 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water Development Corp. Contractor
 Address 1202 Kentucky Avenue Contractor
Woodland, Ca. 95776
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1368
 Signed J. Miller Smith
 By driller performing actual drilling on site or contractor
 Date _____

Date started 1-26, 1994.
 Date completed 2-3, 1994.

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
11.0	14.16'	3

94 MAY 16 P 2:38

STATE ENGINEERS OFFICE

RECEIVED

MAY 18 1994

Div. of Water Resources
 Branch Office - Las Vegas, N