X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

44608 OFFICE USE ONLY
Log No.
Permit No.
Basin 13-207 I

NOTICE OF INTENT NO. 13231

1. OWNER Don Halsted
MAILING ADDRESS HC 34 Box 34150 Ely NV. 89301
ADDRESS AT WELL LOCATION Halsted Ranch Lund Nev

2. LOCATION N/W ¼ S/W ¼ Sec. 17 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. — Issued by Water Resources | — Parcel No. | — Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	15	15
fine sand - boulders		15	40	25
clay - sand		40	75	35
coarse sand - boulders	X	75	117	42
coarse sand - clay		117	130	13
coarse sand - boulders	X	130	145	15
Fractured Rock	X	145	157	12
clay - boulders		157	165	8
clay		165	167	2
TD 167'				

RECEIVED
JUN 7 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-6-94, 19
Date completed 3-9-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300	—	2

STATE ENGINEER'S OFFICE JUL -7 '94

8. WELL CONSTRUCTION
Depth Drilled 167 Feet Depth Cased 167 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	167 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	—	.188	0	167

Perforations:
Type perforation Factory
Size perforation 1/8 x 3"
From 167 feet to 147 feet
From 87 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 167 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling (Contractor)
Address PO Box 54 (Contractor)
Hiko Nev. 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike B Davis (By driller performing actual drilling on site or contractor)
Date 3-10-94

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627