WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44609
Permit No.
Basin 170

NOTICE OF INTENT NO. 10151

1. OWNER Russ Osthus
MAILING ADDRESS HCR Star Route Hiko Nev 89017
ADDRESS AT WELL LOCATION Central Ave. Rachel - Nev 89017

2. LOCATION N/E ¼ S/W ¼ Sec. 36 T. 3 N/S R. 55 E. Lincoln County
PERMIT NO. 0 (Issued by Water Resources) Parcel No. 21 Subdivision Name Sunset Acres

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	18	18
Coarse sand - gravel		18	80	62
Coarse sand - boulders		80	110	30
Fine sand, boulders	X	110	150	40
Clay - sand - boulders	X	150	175	25
Clay		175	178	3

178' TD

RECEIVED
JUN 7 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-30-94, 19
Date completed 4-31-94, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
28	35	3

8. WELL CONSTRUCTION
Depth Drilled 178 Feet Depth Cased 178 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches	Feet	0	178 Feet
Inches	Feet		Feet
Inches	Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	178

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From 138 feet to 138 feet
From 158 feet to 178 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 178' feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling (Contractor)
Address P.O. Box 54 (Contractor)
Hiko Nev. 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike D Davis (By driller performing actual drilling on site or contractor)
Date 5-5-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627