



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT N 12.36.3

1. OWNER Bill Scroggins ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 368 Sandy Lane AMARGOSA NV
Beatty NV 89023 off of Anville Way
 2. LOCATION SW 1/4 SW 1/4 Sec 20 T. 16 N/S R. 49 E. Nye County _____
 PERMIT NO. _____ Parcel No. 19-611-15 Subdivision Name Anville Way Subdivision
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>lava boulders</u>		<u>10</u>	<u>200</u>	<u>190</u>
<u>Sand</u>		<u>190</u>	<u>220</u>	<u>30</u>
<u>White Sand Gravel</u>		<u>220</u>	<u>250</u>	<u>30</u>
<u>Sand & Gravel</u>		<u>250</u>	<u>260</u>	<u>10</u>
<u>Boulders & Sand</u>	<u>264</u>	<u>260</u>	<u>300</u>	<u>40</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 200 Feet
8 Inches 200 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>1 3/8</u>	<u>0</u>	<u>200</u>
<u>6 5/8</u>		<u>1 1/2</u>	<u>133</u>	<u>300</u>

Perforations:
 Type perforation Tool J
 Size perforation 1/4"
 From 260 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 175
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce Robinson Contractor
 Address PO Box 4307 Contractor
PUNO 49041
 Nevada contractor's license number issued by the State Contractor's Board 15972
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
 Signed Bruce Robinson
 By driller performing actual drilling on site or contractor
 Date 5-9-94

Date started 4-6, 1994
 Date completed 5-6, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>150</u>	<u>4</u>

RECEIVED
 JUN 21 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV