



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT ^{in Book}

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10911

1. OWNER John Dilger ADDRESS AT WELL LOCATION McMurry St
 MAILING ADDRESS HCR 77 Box 41526 Lot 29

2. LOCATION N 1/2 1/4 1/4 Sec 28 T. 19S N/S R. 53 E NYE County
 PERMIT NO. 29-891-29 Parcel No. Bell Vista Sub Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	10	10
Caliche		10	15	5
BRN Clay		15	25	10
Caliche		25	35	10
BRN Clay		35	50	15
Caliche		50	60	10
GRAVEL + Clay	WB	60	70	10
Small Caliche	70	70	85	15
BRN Clay		85	105	20
Small GRAVEL Clay	WB	105	130	25
BRN Clay	WB	130	145	15
Caliche		145	150	5
GRAVEL Clay		150	165	15
Caliche		165	170	5
HARD GRAVEL Clay		170	180	10

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From To
12 1/2 Inches 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>11.8</u>	<u>1.88</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4 x 6"

From _____ feet to _____ feet
 From 120 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 180 feet

RECEIVED
 JUN 7 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started April 28 1994
 Date completed May 28 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Nailon Drilling Contractor
 Address Box 265 Pahrump NEV 89041 Contractor
Ron Nailon Drilling

Nevada contractor's license number issued by the State Contractor's Board 0035784
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625

Signed Ron Nailon
 By driller performing actual drilling on site or contractor
 Date May 28 1994