


Log No. 44627
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13278

1. OWNER RHONDA GRAYDON ADDRESS AT WELL LOCATION 1588 SCALES
 MAILING ADDRESS PAHRUMP NV 89041
 2. LOCATION NE SW 1/4 Sec 29 T19S N/S R. 53 E NYE County _____
 PERMIT NO. 27-381-50
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	5	5
CALICHE		5	75	70
CLAY		75	11	64
CALICHE		11	15	4
CLAY		15	32	17
CALICHE		32	37	5
CLAY		37	53	16
CALICHE	WB	53	58	5
CLAY		58	64	6
CALICHE	WB	64	67	3
CLAY		67	78	11
CALICHE	WB	78	81	3
CLAY		81	92	11
CALICHE	WB	92	9	83
CLAY		9	115	106
CALICHE	WB	115	118	3
CLAY		118	129	11
CALICHE	WB	129	140	11
		140		140

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85/8	16.9	.188	0	140

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1 1/8 X 3"
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. INC. Contractor
 Address HCR 78 BOX 80358 Contractor
PAHRUMP NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-10-94



RECEIVED
 JUN 29 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 5-23-94, 19_____
 Date completed 5-27-94, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)