WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44638
Permit No.
Basin 162

NOTICE OF INTENT NO 12898

1. OWNER ALLEN PINNICK
MAILING ADDRESS
ADDRESS AT WELL LOCATION 251 E MELANIE
PAHRUMP NV 89041

2. LOCATION SW ¼ NW ¼ Sec 34 T 19S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 29-852-16 (Parcel No.) RANCHO DEL SOL (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	7	4
CLAY		7	29	22
CALICHIE		29	34	5
CLAY		34	49	15
CALICHIE		49	54	5
CLAY		54	68	14
CALICHIE	WB	68	70	2
CLAY		70	76	6
CALICHIE	WB	76	78	2
CLAY		78	95	17
CALICHIE	WB	95	98	3
CLAY		98	103	5
CALICHIE	WB	103	108	5
CLAY		108	117	9
CALICHIE	WB	117	124	7
CLAY		124	129	5
CALICHIE	WB	129	140	11
		140		140

RECEIVED
JUN 29 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-16-94, 19
Date completed 5-20-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
121\4	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 8035B (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on site or contractor)
Date 6-10-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627