

44660
 OFFICE USE ONLY
 Log No. 44660
 Permit No.
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13036

1. OWNER B & L Properties ADDRESS AT WELL LOCATION Windsong Drive
 MAILING ADDRESS Pahrump, NV 89041 Pahrump, NV 89041
 2. LOCATION N-E 1/4 N-W 1/4 Sec 13 T. 20 S N/S R. 52 E Nye County
 PERMIT NO. 28-791-17 Charleston Park Unit 2
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------------|--------------|-----------|------------|-----------|
| <u>Soil</u> | | <u>0</u> | <u>8</u> | <u>8</u> |
| <u>Brown Clay</u> | | <u>8</u> | <u>45</u> | <u>37</u> |
| <u>Grey Clay</u> | <u>X</u> | <u>45</u> | <u>70</u> | <u>25</u> |
| <u>Light Brown Clay</u> | <u>X</u> | <u>70</u> | <u>90</u> | <u>20</u> |
| <u>Grey Clay</u> | <u>X</u> | <u>90</u> | <u>140</u> | <u>50</u> |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 140 Feet
 From 0 Feet To 140 Feet
 From 0 Feet To 140 Feet
 From 0 Feet To 140 Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8</u> | <u>17</u> | <u>188</u> | <u>0</u> | <u>140</u> |

Perforations:
 Type perforation Factory
 Size perforation 3 X 16 X 4"
 From 140 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 MAY 20 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started April 27 1994
 Date completed April 30 1994

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|-----------------|
| <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>30</u> | <u>5</u> | <u>1/2 Hour</u> |

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry's Water Well service Contractor
 Address P.O. Box 3392 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Larry H. Jenkins
 By Larry H. Jenkins performing actual drilling on site or contractor
 Date April 30 1994