WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44679
Permit No.
Basin

NOTICE OF INTENT NO. 13018

1. OWNER Don Jansson
MAILING ADDRESS P.O. Box 3000 #118
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
Shadow Mt. Street
Pahrump, NV 89041

2. LOCATION N-W ¼ S-W ¼ Sec. 6 T. 20 S N/S R. 53 E E N/E County
PERMIT NO. (Issued by Water Resources) 36-533-03 (Parcel No.) Shadow Mt. Lot # 2 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	67	67
Light Brown Clay	X	67	140	73

RECEIVED
MAY 26 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-10, 19 94
Date completed 5-13, 19 94

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	2	½

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation Factory
Size perforation 3X16X4"
From 140 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 54' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry's Water Well Service (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board I
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry H Jenkins (By driller performing actual drilling on site or contractor)
Date 5-13-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627